



OMEGA INSPECTION & ANALYTICAL LABORATORY



Our Esteemed Customers : HYUNDAI, FORD, NISSAN, TOYOTA, MAHINDRA & MAHINDRA, WIPRO, IBR, DGQA, BHEL, BV, IRS, BIS, EIL, LLOYDS, NLC, RITES, CPWD, CMWSSB, PWD, TWAD, AAI, S.RLY., PORT TRUST, NABARD, NHAI, MILITARY (MES), Etc.,

T.S. No. 57 & 58, Guindy Industrial Estate, Guindy, Chennai - 600 032. INDIA. Phone : 044 - 2250 0127
Telefax : 044 - 2250 0523, Mobile : 94442 55041, E-mail : omega_jal@outlook.com Web : www.omegalab.in

TOCR NO.16- 1217

Date.08.06.16

TR No.06- 2330

Test Report

Moisture Movement in Autoclaved Aerated Concrete Blocks

The Client * : M/s. Fusion Building Materials Private Ltd
New No.6, Old No.27, 2nd Lane, Pasumathy Street,
Kodambakkam, Chennai - 600 024.

Source of samples* : Samples drawn by customer

Customer Reference * : No.Nil,Dtd.08.06.16

Sample Details * : 300 x 100 x 200mm

No.of Samples tested : 3 Nos

Period of Test : 01.06.16 to 07.06.16

Technical Reference : IS 2185 (Part 3) & IS 2185 (Part 1)

Sl No.	Brand *	Blocks Moisture in (%)
1	Fusion	0.03
2	Fusion	0.02
3	Fusion	0.03
(Only three samples tested)		

* As furnished by the customer

Remarks : The moisture movement of the dried blocks on immersion in water, being the average of three units, when detrimined in the manner described in IS 2185 (Part I) Annexure G shall not exceed 0.09 Percent.


R. Dileesh Kumar
Engineer
Tested & Verified



for Omega Inspeccion & Analytical Laboratory


(K.M. Balasubramanian)
Chief Executive Officer

Note: Certified that the test enumerated above have been carried out in conformity with standard testing procedures and relevant specifications. The Certificate refers ONLY to the particular sample(s) submitted for test. Sample description is not verified in all cases and is given as described by customer. All complaints about this should be communicated in writing within 10 days from the date of issue of this report. The report shall be reproduced expect in full, without the written approval of OIAL.



OMEGA INSPECTION & ANALYTICAL LABORATORY



Our Esteemed Customers : HYUNDAI, FORD, NISSAN, TOYOTA, MAHINDRA & MAHINDRA, WIPRO, IBR, DGQA, BHEL, BV, IRS, BIS, EIL, LLOYDS, NLC, RITES, CPWD, CMWSSB, PWD, TWAD, AAI, S.R.LY., PORT TRUST, NABARD, NHAI, MILITARY (MES), Etc.,

T.S. No. 57 & 58, Guindy Industrial Estate, Guindy, Chennai - 600 032. INDIA. Phone : 044 - 2250 0127
Telefax : 044 - 2250 0523, Mobile : 94442 55041, E-mail : omega_ial@outlook.com Web : www.omegalab.in

TOCR NO.16- 1217

Date.08.06.16

TR No.06- 2331

Test Report

Moisture Movement in Autoclaved Aerated Concrete Blocks

The Client * : M/s. Fusion Building Materials Private Ltd
New No.6, Old No.27, 2nd Lane, Pasumathy Street,
Kodambakkam, Chennai - 600 024.

Source of samples* : Samples drawn by customer

Customer Reference * : No.Nil,Dtd.08.06.16

Sample Details * : 300 x 150 x 200mm

No.of Samples tested : 3 Nos

Period of Test : 01.06.16 to 07.06.16

Technical Reference : IS 2185 (Part 3) & IS 2185 (Part 1)

Sl No.	Brand *	Blocks Moisture in (%)
1	Fusion	0.01
2	Fusion	0.02
3	Fusion	0.02
(Only three samples tested)		

* As furnished by the customer

Remarks : The moisture movement of the dried blocks on immersion in water, being the average of three units, when detrimined in the manner described in IS 2185 (Part I)Annexure G, shall not exceed 0.09 Percent.

R. Dinesh Kumar
Engineer

Tested & Verified



for Omega Inspeccion & Analytical Laboratory

K.M. Balasubramanian
(K.M.Balasubramanian)
Chief Executive Officer

Note: Certified that the test enumerated above have been carried out in conformity with standard testing procedures and relevant specifications. The Certificate refers ONLY to the particular sample(s) submitted for test. Sample description is not verified in all cases and is given as described by customer. All complaints about this should be communicated in writing within 10 days from the date of issue of this report. The report shall be reproduced expect in full, without the written approval of OIAL.



OMEGA INSPECTION & ANALYTICAL LABORATORY



Our Esteemed Customers : HYUNDAI, FORD, NISSAN, TOYOTA, MAHINDRA & MAHINDRA, WIPRO, IBR, DGQA, BHEL, BV, IRS, BIS, EIL, LLOYDS, NLC, RITES, CPWD, CMWSSB, PWD, TWAD, AAI, S.RLY., PORT TRUST, NABARD, NHAI, MILITARY (MES), Etc.,

T.S. No. 57 & 58, Guindy Industrial Estate, Guindy, Chennai - 600 032. INDIA. Phone : 044 - 2250 0127
Telefax : 044 - 2250 0523, Mobile : 94442 55041, E-mail : omega_ial@outlook.com Web : www.omegalab.in

TOCR NO.16- 1217

Date.08.06.16

TR No.06- 2332

Test Report

Moisture Movement in Autoclaved Aerated Concrete Blocks

The Client * : M/s. Fusion Building Materials Private Ltd
New No.6, Old No.27, 2nd Lane, Pasumathy Street,
Kodambakkam, Chennai - 600 024.

Source of samples* : Samples drawn by customer

Customer Reference * : No.Nil,Dtd.08.06.16

Sample Details * : 300 x 200 x 200mm

No.of Samples tested : 3 Nos

Period of Test : 01.06.16 to 07.06.16

Technical Reference : IS 2185 (Part 3) & IS 2185 (Part 1)

Sl No.	Brand *	Blocks Moisture in (%)
1	Fusion	0.02
2	Fusion	0.04
3	Fusion	0.03
(Only three samples tested)		

* As furnished by the customer

Remarks : The moisture movement of the dried blocks on immersion in water, being the average of three units, when detrimined in the manner described in IS 2185 (Part I)Annexure G, shall not exceed 0.09 Percent.

R. Dhivya Kumar
Engineer
Tested & Verified



for Omega Inspection & Analytical Laboratory

K.M. Balasubramanian
(K.M.Balasubramanian)
Chief Executive Officer

Note: Certified that the test enumerated above have been carried out in conformity with standard testing procedures and relevant specifications. The Certificate refers ONLY to the particular sample(s) submitted for test. Sample description is not verified in all cases and is given as described by customer. All complaints about this should be communicated in writing within 10 days from the date of issue of this report. The report shall be reproduced expect in full, without the written approval of OIAL.



OMEGA INSPECTION & ANALYTICAL LABORATORY



Our Esteemed Customers : HYUNDAI, FORD, NISSAN, TOYOTA, MAHINDRA & MAHINDRA, WIPRO, IBR, DGQA, BHEL, BV, IRS, BIS, EIL, LLOYDS, NLC, RITES, CPWD, CMWSSB, PWD, TWAD, AAI, S.RLY., PORT TRUST, NABARD, NHAI, MILITARY (MES), Etc.,

T.S. No. 57 & 58, Guindy Industrial Estate, Guindy, Chennai - 600 032. INDIA. Phone : 044 - 2250 0127
Telefax : 044 - 2250 0523, Mobile : 94442 55041, E-mail : omega_ial@outlook.com Web : www.omegalab.in

TOCR NO.16- 1217

Date.08.06.16

TR No.06- 2333

Test Report

Moisture Movement in Autoclaved Aerated Concrete Blocks

The Client * : M/s. Fusion Building Materials Private Ltd
New No.6, Old No.27, 2nd Lane, Pasumathy Street,
Kodambakkam, Chennai - 600 024.

Source of samples* : Samples drawn by customer

Customer Reference * : No.Nil,Dtd.08.06.16

Sample Details * : 300 x 230 x 200mm

No.of Samples tested : 3 Nos

Period of Test : 01.06.16 to 07.06.16

Technical Reference : IS 2185 (Part 3) & IS 2185 (Part 1)

Sl No.	Brand *	Blocks Moisture in (%)
1	Fusion	0.04
2	Fusion	0.04
3	Fusion	0.02
(Only three samples tested)		

* As furnished by the customer

Remarks : The moisture movement of the dried blocks on immersion in water, being the average of three units, when detrimined in the manner described in IS 2185 (Part I)Annexure G, shall not exceed 0.09 Percent.

R. Dharmaraj Kumar
Engineer
Tested & Verified



for Omega Inspeccion & Analytical Laboratory

(K.M.Balasubramanian)
Chief Executive Officer

Note: Certified that the test enumerated above have been carried out in conformity with standard testing procedures and relevant specifications. The Certificate refers ONLY to the particular sample(s) submitted for test. Sample description is not verified in all cases and is given as described by customer. All complaints about this should be communicated in writing within 10 days from the date of issue of this report. The report shall be reproduced expect in full, without the written approval of OIAL.