



Dr. B. NAGESWARA RAO
Professor & Head of Structural Engineering Laboratory

STRUCTURAL ENGINEERING DIVISION
DEPARTMENT OF CIVIL ENGINEERING
INDIAN INSTITUTE OF TECHNOLOGY MADRAS
CHENNAI - 600 036 INDIA
Tel: 044 - 2257 4285 (O)
Fax: 044 -22574252
Email: bnrao@iitm.ac.in

TEST REPORT OF ANALYSIS OF WATER SAMPLE

Client : M/s Fusion Building Materials Private Limited
Source of specimens : Supplied by client
Condition of samples : Satisfactory
Letter Dated : 03.03.2017
Date of testing : 11.03.2017
Test Method Followed : IS 456- 2000 (Reaffirmed 2005) and IS: 3025- 1983
(Part 11, 15, 16, 17, 18, 23, 24 & 32)

Observed Values:

Sl. No.	Particulars	Results	Stipulations of IS: 456- 2000 (Water for construction purpose)
1	Chlorides as Cl	3029.06	500 mg/l max. for RCC 2000 mg/l max. fro PCC
2	Sulphates as SO_3	354	400 mg/l max.
3	Suspended matter	20	2000 mg/l max.
4	Organic Solids	3980	200 mg/l max.
5	Inorganic Solids	4640	3000 mg/l max.
6	pH Value	7.61	Shall not be less than 6

Remarks:

The tested water sample does not conform to the requirements of IS: 456-2000 for RCC and PCC

Note:

This certificate is based on the sample submitted for testing.



Dr. B. NAGESWARA RAO
Professor
Department of Civil Engineering
Indian Institute of Technology Madras
Chennai - 600 036, India